



Items looked at upon Occupancy

- 1) Exit signs must be lighted and emergency lights must work on battery.
- 2) Storage must be at least 30 inches from all mechanical equipment.
- 3) There should be no open electric and extension cords should be replaced with power strips that have a built-in surge protector.
- 4) The exits should not be blocked and the keys in the Knox Box must be updated.
- 5) Buildings with any of the following equipment should also have: Annual Fire Extinguisher service, Annual Fire sprinkler testing, Annual Fire alarm testing, Annual Elevator inspection, Annual Generator testing. Kitchen hood and Fire suppression service.
- 6) 6 inch address (white on glass)